

DEPARTMENT OF BUILDING SERVICES ENGINEERING 屋宇設備工程學系

DIMON Technology Ltd.
Suite 14, 11/F, Cheung Hing Industrial Building
23 Tai Yip Street, Kwun Tong
Kowloon
Hong Kong

Our reference: BL-HW-20-R392

Issue date: 11 August 2020

The luminaire supplied by you was inspected on 11 August 2020 and the results were presented as follows;

Description of luminaire: "DIMON" LED weatherproof downlight DSAR series self-

contained emergency LED downlight

Complete set model: DSAR-5W; DSAR-6W; DSAR-7W; DSAR-8W;

DSAR-9W; DSAR-10W; DSAR-11W; DSAR-12W; DSAR-13W; DSAR-14W; DSAR-15W; DSAR-16W; DSAR-17W; DSAR-18W; DSAR-19W; DSAR-20W; DSAR-21W; DSAR-22W; DSAR-23W; DSAR-24W; DSAR-25W; DSAR-26W; DSAR-27W; DSAR-28W; DSAR-29W; DSAR-30W; DSAR-31W; DSAR-32W; DSAR-33W; DSAR-34W; DSAR-35W; DSAR-36W; DSAR-37W; DSAR-38W; DSAR-39W; DSAR-40W; DSAR-41W; DSAR-42W; DSAR-43W; DSAR-44W; DSAR-45W; DSAR-46W; DSAR-47W; DSAR-48W; DSAR-49W; DSAR-50W; DSAR-51W; DSAR-56W; DSAR-57W; DSAR-56W; DSAR-57W; DSAR-56W; DSAR-57W; DSAR-56W; DSAR-57W; DSAR-56W; DSAR-57W; DSAR-56W; DSAR-55W; DSAR-60W

Input: AC 220V +/-10% 50Hz

Case: The case is made of die-cast aluminium and 8mm clear

tempered glass

Investigations requested: Test on luminaire to comply with part A11 of FSD regulation

PPA104 (4th revision) and B3 of FSD regulation PPA 104(A)

(4th revision)

BL-HW-20-R392 44054(0)

1



DEPARTMENT OF BUILDING SERVICES ENGINEERING 屋宇設備工程學系

Test results

The hot wire test equipment we used complies with IEC60695-2-10:2013 and the test was carried out according to the procedures described in IEC60695-2-10:2013 with a hot wire temperature of 850°C.

The luminaire was inspected in our laboratory and it complied with relevant sections of clause 13.3.2 of BS EN 60598-1:2015 and clause 22.16 of BS EN 60598-2-22:2014 and therefore passed part A11 of FSD regulation PPA104 (4th revision) and part B3 of FSD regulation PPA 104(A) (4th revision).

Dr Hilda Cheung Hiu Dan

Instructor

Department of Building Services Engineering

www.bse.polyu.edu.hk