



DIMON Technology Ltd.  
Suite 14, 11/F, Cheung Hing Industrial Building  
23 Tai Yip Street, Kwun Tong  
Kowloon  
Hong Kong

Our reference: BL-HW-19-T161

Issue date: 18 October 2019

The luminaire supplied by you was inspected in our laboratory on 16 October 2019 and the results were presented as follows;

Description of luminaire: "Dimon" self-contained emergency weatherproof batten

Complete set model: BAWATY-6W-EM, BAWATY-7W-EM,  
BAWATY-8W-EM, BAWATY-9W-EM,  
BAWATY-10W-EM, BAWATY-12W-EM,  
BAWATY-14W-EM, BAWATY-16W-EM,  
BAWATY-18W-EM, BAWATY-20W-EM,  
BAWATY-24W-EM, BAWATY-28W-EM,  
BAWATY-30W-EM, BAWATY-32W-EM,  
BAWATY-36W-EM, BAWATY-40W-EM

Input: AC 220V +/-10%, 50Hz

Case: The case is made of polycarbonate housing and diffuser

Investigations requested: Test on luminaire to comply with part A11 of FSD regulation PPA104 (4<sup>th</sup> revision) and B3 of FSD regulation PPA 104A (4<sup>th</sup> revision)



## Test results

For the flammable parts of the luminaire, a small piece was cut out. The sample was placed in the hot-wire test chamber to carry out the hot wire test.

The hot wire test equipment we used complies with IEC60695-2-10:2013 and the test was carried out according to the procedures described in IEC60695-2-10:2013 with a hot wire temperature of 850°C.

Test results for flammable parts: The test sample ignited under the hot wire, but when the hot wire withdrew from the sample, the flame extinguished within 30 s. There were no burning drops falling down from the sample.

The luminaire was inspected in our laboratory and it complied with clause 13.3.2 of BS EN 60598-1:2015 and clause 22.16 of BS EN 60598-2-22:2014 and therefore passed part A11 of FSD regulation PPA104 (4<sup>th</sup> revision) and part B3 of FSD regulation PPA 104A (4<sup>th</sup> Rev).



Dr Hilda Cheung Hiu Dan  
Instructor  
Department of Building Services Engineering